

## **Office of the State Fire Marshal (OSFM) Example Inspection Checklist**

- 1 Extinguisher Required Not Present 2A:10BC “K”**  
NFPA 101/2015 / 11.11.5  
Part 150.70 f  
Vendor Exhibitor Information booklet Page 12  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1 & 2
- 2 Extinguisher Not Tagged / Not Current A:10BC “K”**  
NFPA 10/2007  
Part 150.80 d 10  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1
- 3 Non-Approved Cooking Equipment being used**  
Part 270.125  
Part 150.50 a 5  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 2  
NFPA 96 / 2008
- 4 Cooking Shielding/Separation Distance not met**  
2023 Temporary Food Stand Food Safety Guidelines page 1 & 2  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 2  
NFPA 96 / 2008
- 5 Suppression System Not Tagged / Not Current**  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 2  
NFPA 96 / 2008
- 6 Smoking in unauthorized area, No Smoking Signs not present**  
Part 270.360  
NFPA 101/2015 / 11.11.4.2.2  
Part 150.80 f 2 A  
Vendor Exhibitor Information Booklet Page 12  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1
- 7 # LPG tanks allowed are exceeded (Maximum of 6)**  
NFPA 58/2011 / 6.4.2  
Vendor Exhibitor Information Booklet Page 10
- 8 LPG Tanks Not Secured Properly / Upright**  
NFPA 101/2015 / 11.11.6.1.4  
Part 200 / NFPA 58 (2011)  
Vendor Exhibitor Information Booklet Page 12  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 4
- 9 LPG Tank inside building or vendor space**  
Part 270.95 / Part 270.515  
Part 150.60 a 2  
NFPA 101/2015 / 11.11.6.1.3  
Part 200 / NFPA 58 (2011)  
Vendor Exhibitor Information Booklet Page 10
- 10 Flammable / Combustible Liquid Use / Storage**  
Vendor Exhibitor Information Booklet Page 11  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1&5

- 11 Ungrounded / Lightweight extension cord(s) being used**  
Part 270.110  
Part 150.80 f 2 B  
NFPA 70 (2014)  
Vendor Exhibitor Information Booklet Page 10  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1&3
- 12 Misc. Electrical Violations**  
Part 270.110 / Part 270.240  
NFPA 70 (2014)  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1&3
- 13 Exits Obstructed / Blocked**  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1
- 14 Tent Material Not Rated / No Proof of Rating**  
NFPA 101/2015 / 11.11.2.1  
Vendor Exhibitor Information Booklet Page 11  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 3
- 15 Non - Approved Trash Containers in use**  
Part 150.80 c 2  
Vendor Exhibitor Information Booklet Page 12  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1
- 16 Fire Lane Obstructed / Blocked**  
Part 270.335 / Part 270.345  
Part 150.80 f 2 H  
Vendor Exhibitor Information Booklet Page 12  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1
- 17 Hydrant Obstructed / Blocked**  
Part 150.70 b 3/4 and Part 150.80 f 2 K  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1
- 18 Sleeping, cooking in unauthorized areas, Barn aisles blocked**  
Part 270.360 / Part 270.665  
Part 150.60 a 5  
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2023 - page 1