

Office of the State Fire Marshal (OSFM) Example Inspection Checklist

- 1 Extinguisher Required Not Present 2A:10BC “K”**
NFPA 101/2015 / 11.11.5
Part 150.70 F
Vendor Exhibitor Information booklet Page 12
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1 & 2
- 2 Extinguisher Not Tagged / Not Current A:10BC “K”**
NFPA 10/2007
Part 150.80 D 10
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1
- 3 Non-Approved Cooking Equipment being used**
Part 270.125
Part 150.50 A 5 / 6
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 2
NFPA 96 / 2008
- 4 Cooking Shielding/Separation Distance not met**
ISF 2021 Food Safety Fact Sheet for Vendors / Temporary Food Stand Food Safety Guidelines page 1 & 2
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 2
NFPA 96 / 2008
- 5 Suppression System Not Tagged / Not Current**
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 2
NFPA 96 / 2008
- 6 Smoking in unauthorized area, No Smoking Signs not present**
Part 270.360
NFPA 101/2015
Part 150.80 F 2 A
Vendor Exhibitor Information Booklet Page 12
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1
- 7 # LPG tanks allowed are exceeded (Maximum of 6)**
NFPA 58/2011 / 6.4.2
Vendor Exhibitor Information Booklet Page 10
- 8 LPG Tanks Not Secured Properly / Upright**
NFPA 101/2015 / 11.11.6.1.4
Part 200 / NFPA 58 (2011)
Vendor Exhibitor Information Booklet Page 12
State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1&4
- 9 LPG Tank inside building or vendor space**
Part 270.95 / Part 270.515
Part 150.60 A 2
NFPA 101/2015 / 11.11.6.1.3

10 Flammable / Combustible Liquid Use / Storage

Vendor Exhibitor Information Booklet Page 11

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1&5

11 Ungrounded / Lightweight extension cord(s) being used

Part 270.110

Part 150.80 F 2 b

NFPA 70 (2014)

Vendor Exhibitor Information Booklet Page 10

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1&3

12 Misc. Electrical Violations

Part 270.110 / Part 270.240

NFPA 70 (2014)

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1&3

13 Exits Obstructed / Blocked

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1

14 Tent Material Not Rated / No Proof of Rating

NFPA 101/2015 / 11.11.2.1

Vendor Exhibitor Information Booklet Page 11

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 3

15 Non - Approved Trash Containers in use

Part 150.80 C 2

Vendor Exhibitor Information Booklet Page 12

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1

16 Fire Lane Obstructed / Blocked

Part 270.335 / Part 270.345

Part 150.80 F 2 H

Vendor Exhibitor Information Booklet Page 12

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1

17 Hydrant Obstructed / Blocked

Part 150.70 B 3/4 and Part 150.80 F 2 K

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1

18 Sleeping, cooking in unauthorized areas, Barn aisles blocked

Part 270.360 / Part 270.665

Part 150.60 A 5

State Fire Marshal: Requirements for all Concessionaires / Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025-page 1